

भारतीय प्रौद्योगिकी संस्थान गुवाहाटी

Indian Institute of Technology Guwahati गुवाहाटी - 781 039, असम

Phone: (0361) 2582061, 2582075 Fax: (0361) 2692771

Infrastructure, Planning and Management(IPM) अवसंरचना, योजना एवं प्रबंधन (आई पी एम) अनुभाग

Date: 14/07/2021

CORRIGENDUM

Name of Work: Supply, installation, testing & commissioning of modular type UPS unit for Data Centre at IIT Guwahati

NIT No.: IITG/IPM/NIT/C/2021/09 Dated: 21.06.2021

- 1. The date and time for download, submission and opening of the tender has been rescheduled as below:
 - i. Extended date of download of the tender paper upto 10.29 hrs of 19.07.2021
 - ii. Last date and time of submission of the tender: 10.30 hrs on 19.07.2021
 - iii. Date and time of opening of the tender: 11.00 hrs on 19.07.2021
- 2. Following corrections were made in the uploaded tenders (Financial Bid) of the above said work:
 - 2.1. The item no. 1.2 & 2.1 of Financial Bid has been revised as follows and to be included in the financial bid of the tender replacing the earlier one. The revised clause is as follows:

In the existing Tender	To be read as
Item No.: 1.2 of BOQ	Item No.: 1.2 of BOQ
Supply, Installation, Testing, commissioning of	Supply, Installation, Testing, commissioning of
2 years' warranty for 12V SMF Battery with	2 years' warranty for 12V SMF Battery with
Battery sizing at 200kVA/180kW i.e.0.9 PF, and	Battery sizing at 200kVA/180kW i.e.0.9 PF,
ECV: 1.7V with 30 min back up at Standard	and ECV: 1.7V with 15 min back up at
Operating Life (SOL).	Standard Operating Life (SOL).
Item No.: 2.1 of BOQ	Item No.: 2.1 of BOQ
20KVA online UPS 3Ph In and 1 Ph out with	20KVA online UPS 3Ph In and 1 Ph out with
inbuilt ISOLATION TRANSFORMER with 30	inbuilt ISOLATION TRANSFORMER with 15
min backup for support systems.	min backup for support systems.

- 3. Bidders are requested to submit their bids as instructed above.
- 4. All other items and terms & conditions will remain same as per NIT and corrigendums issued from time to time.

HOS (IPM)